



NOTICE OF REVIEW

APDES Preliminary Draft Permit

Alaska Department of Environmental Conservation (DEC)
Wastewater Discharge Authorization Program
555 Cordova Street
Anchorage, Alaska 99501

NOTICE OF REVIEW OF AN
ALASKA POLLUTANT DISCHARGE ELIMINATION SYSTEM (APDES)
PRELIMINARY DRAFT PERMIT
TO DISCHARGE TO WATERS OF THE UNITED STATES

ADEC has prepared an APDES preliminary draft permit for the Homer Wastewater Treatment Facility. The Preliminary Draft Permit and associated documents are available to the applicant for a 10-day review. Following the close of the 10-day applicant review period, DEC will prepare a draft permit and fact sheet for a formal 30-day public review period. Public comments will be accepted during the formal 30-day review period. You can access the documents on DEC's Wastewater Discharge Authorization Program webpage at:

<http://www.dec.state.ak.us/water/wwdp/index.htm>

DEC Contact:

Marie Klingman
610 University Avenue
Fairbanks, Alaska 99709
(907) 451-2101
marie.klingman@gmail.com

Preliminary Draft Permit Review:

Start Date: May 10, 2016

End Date: May 24, 2016

Permit No.: AK0021245

Applicant:

City of Homer
Homer Wastewater Treatment Facility
3575 Heath Street
Homer, AK 99603

Proposed Project and Location:

The discharge of secondary treated domestic wastewater from the Homer Wastewater Treatment Facility located at 59° 37' 58" North and 151° 32' 52" West will occur at an average monthly rate of 880,000 gallons per day to Kachemak Bay. A mixing zone is proposed for ammonia and fecal coliform bacteria.

Administrative Record:

The APDES preliminary draft permit, fact sheet, and associated documents are available for public review at the ADEC offices located in Anchorage, Fairbanks, Juneau, Soldotna, and Wasilla. Please contact the office of your choice to arrange for hard copies of the documents to be available for your review.

555 Cordova Street
Anchorage, AK 99501
907-269-6285

610 University Avenue
Fairbanks, AK 99709
907-451-2100

410 Willoughby Ave #303
Juneau, AK 99811
907-465-5300

43335 Kalifornsky Beach Road
Soldotna, AK 99615
907-262-5210

1700 E Bogard Road #B
Suite #103
Wasilla, AK 99654
907-376-1850

If you would like to see any additional supporting technical documents, contact the DEC contact listed above.

The documents are also accessible from the DEC website at:

<http://www.dec.state.ak.us/water/wwdp/index.htm>

Disability Reasonable Accommodation Notice

The State of Alaska, Department of Environmental Conservation complies with Title II of the Americans with Disabilities Act of 1990. If you are a person with a disability who may need a special accommodation in order to participate in this review, please contact Natalie Wolfe at (907) 269-0291 or TDD Relay Service 1-800-770-8973/TTY or dial 711 within 10 days of publication of this notice to ensure that any necessary accommodations can be provided.